



THRUST RESTRAINT DESIGN NOTES

*NOTE: THE CITY OF LEESBURG REQUIRES RESTRAINTS IN ALL DIRECTIONS ON ALL PIPE SIZES 4" OR LARGER. A MINIMUM OF 3 JOINT RESTRAINTS **WITH PRIOR APPROVAL BY THE CITY OF LEESBURG** (NOT TO INCLUDE THE MEGA-LUG AT MJ FITTING) UNLESS DEAD END, 90°, TEE OR REDUCER IS PRESENT WHERE PIPE MINIMUM WILL BE RESTRAINED 100' IN EACH DIRECTION. JOINT RESTRAINTS SHALL BE MEGA-LUG AND MODEL NUMBER SHALL BE FULLY COMPATIBLE WITH THE PIPING MATERIAL BEING RESTRAINED.

BELL RESTRAINT DETAILS

NOT TO SCALE



LEESBURG
The Lakefront City

**City of Leesburg
Standard Details**

2024

Detail G-2