

Oil, Water and Sand Separators

- 1. Access for monitoring the inlet and outlet pipe fittings or baffles shall be provided from manholes. Cleanouts shall be installed before the first Oil and Sand Separator and within two feet after the last interceptor in the series.**
- 2. Oil/ Sand Separator shall be designed to produce a clarified effluent acceptable to the City of Leesburg Standards.**
- 3. All piping and venting shall be in accordance with the Florida Plumbing Code, Latest Edition.**
- 4. Design of the Sand/Sand Separator shall be in accordance with chapter 64E-6 of the Florida Administrative Codes and any and all Applicable Provision of the most recent Addition of the Florida Unified Building Codes.**
- 5. All water and Oil/Sand Separators shall be vented in accordance with all Provision of the Above note # 4.**

City of Leesburg Standard Details