



NOTES:

1. THE MINIMUM DIMENSION FROM TOP OF PIPE TO FINISHED GRADE SHALL BE 3.0 FEET.
2. DOUBLE STRAP SADDLE AND WRAP WITH TWO LAYERS OF WIDE PLASTIC OR POLY TAPE WITH STAINLESS STEEL STRAP.
3. PIPE INSTALLATION SHALL BE SUCH THAT THE ARV IS LOCATED AT THE HIGHEST POINT IN THE RESPECTIVE SEGMENT.
4. INTERIOR AND EXTERIOR CONCRETE SURFACES SHALL RECEIVE PROTECTIVE COATING AS SPECIFIED FOR STANDARD MANHOLES.
5. COVER SHALL READ "REUSE WATER".

**COMBINATION AIR RELEASE
& AIR / VACUUM VALVE
FOR REUSE MAINS**

NOT TO SCALE



LEESBURG

The Lakefront City

City of Leesburg
Standard Details

2024

Detail R-2