



*NOTE:

1. SEE THRUST RESTRAINT DETAILS FOR RESTRAINED LENGTH.
2. TUBING DEFLECTIONS SHALL NOT EXCEED 75% OF THAT RECOMMENDED BY MANUFACTURER.

2" RECLAIMED WATER BLOWOFF DETAIL

NOT TO SCALE



LEESBURG

The Lakefront City

City of Leesburg

Standard Details

2024

Detail R-7