



SECTION



PROFILE

NOTE:

1. SIDEWALK CONSTRUCTION SHALL CONFORM TO FDOT STANDARD INDEX 310, UNLESS A MORE STRINGENT STANDARD IS REQUIRED HEREIN OR IN THE CITY OF LEESBURG CONSTRUCTION STANDARD SPECIFICATIONS.
2. COMPACT UPPER 12" OF SUBGRADE TO MINIMUM 98% MODIFIED PROCTOR DRY DENSITY, ASTM D1557.
3. MINIMUM THICKNESS SHALL BE 4 INCHES, DRIVEWAYS AND OTHER TRAFFIC BEARING AREAS SHALL HAVE A MINIMUM THICKNESS OF 6 INCHES

CONCRETE WALKWAY DETAIL

NOT TO SCALE



LEESBURG
The Lakefront City

City of Leesburg
Standard Details

2024

DETAIL ST- 6