



NOTES:

1. ALL PIPE AND FITTINGS SHALL BE THREADED SCHEDULE 40 GALVANIZED STEEL OR BRASS.
2. SIZE OF BACKFLOW PREVENTER ASSEMBLY SHALL MATCH SERVICE LINE SIZE.

WATER

REDUCED PRESSURE BACKFLOW PREVENTER 3/4" TO 2"

NOT TO SCALE



LEESBURG
The Lakefront City

City of Leesburg
Standard Details

2024

Detail W-10