



***NOTE:**

1. HYDRANTS LOCATED BEYOND THE REQUIRED 9' AS SPECIFIED IN C.O.L. CONSTRUCTION SPECIFICATION 10.32, SHALL HAVE A 60" INDICATOR / REFLECTOR PLACED BEHIND FIRE HYDRANT, OR HAVE A REFLECTIVE COLLAR ON THE FIRE HYDRANT FOR LOCATION / IDENTIFICATION PURPOSES.

WATER

FIRE HYDRANT REFLECTOR DETAIL

NOT TO SCALE



LEESBURG
The Lakefront City

**City of Leesburg
Standard Details**

2024

Detail W-12