



NOTES:

1. THE CONTRACTOR SHALL CONTACT THE INSPECTOR FOR EXACT ASSEMBLY LENGTH AND HEIGHT ABOVE THE SLAB REQUIRED FOR THE FIRE LINE MASTER METER TO BE INSTALLED BY THE CONTRACTOR TO CITY SPECIFICATIONS. ALL OTHER PIPE, FITTINGS AND APPURTENANCES SHALL BE INSTALLED BY THE CONTRACTOR.
2. ALL THE ABOVE GROUND PIPE SHALL BE FLANGED DUCTILE IRON.
3. DOUBLE CHECK BFP TO BE HERSEY MODEL DDC II OR APPROVED EQUAL.
4. DOUBLE CHECK BFP HEIGHT TO BE 12" MINIMUM FOR 3" OR LARGER FIRE LINE THE HEIGHT SHALL BE 24".

WATER

FIRE LINE MASTER METER ASSEMBLY 3" OR LARGER

NOT TO SCALE



LEESBURG

The Lakefront City

City of Leesburg Standard Details

2024

Detail W-13