










OTHER PIPE	HORIZONTAL SEPARATION	CROSSING (1)	JOINT SPACING @ CROSSINGS (FULL JOINT CENTERED)
Storm Sewer, Stormwater Force Main, Reclaimed Water (2)	 <p>Water Main</p> <p>3 ft. minimum</p>	 <p>Water Main</p> <p>12 inches is the minimum except for storm sewer, then 6 inches is the minimum and 12 inches is preferred</p>	 <p>Alternate 3 ft. minimum</p> <p>Water Main</p>
Vacuum Sanitary Sewer,	 <p>Water Main</p> <p>10 ft. preferred 3 ft. minimum</p>	 <p>Water Main</p> <p>12 inches is preferred 6 inches minimum</p>	 <p>Alternate 3 ft. minimum</p> <p>Water Main</p>
Gravity or Pressure Sanitary Sewer, Sanitary Sewer Force Main Reclaimed Water (4)	 <p>Water Main</p> <p>10 ft. preferred 6 ft. minimum (3)</p>	 <p>Water Main</p> <p>12 inches is the minimum except for gravity sewer, then 6 inches is the minimum and 12 inches is preferred</p>	 <p>Alternate 6 ft. minimum</p> <p>Water Main</p>
On-Site Sewer Treatment & Disposal System	10 ft. minimum	----	----

- (1) Water main should cross over other pipe. When water main must be below other pipe, the minimum separation is 12 inches.
- (2) Reclaimed water regulated under Part III of Chapter 62-610, F.A.C.
- (3) 3 ft. for gravity sanitary sewer where the bottom of the water main is laid at least 6 inches above the top of the gravity sanitary sewer.
- (4) Reclaimed water not regulated under Part III of Chapter 62-610, F.A.C.
- (5) If watermain is less than 18" above sanitary or storm sewer, reuse or sewerage forcemain pipe at a crossing, then center one full length joint of d.i.p. on crossing point.
- (6) All piping clearances shall be in accordance with chapter 62-555.314, f.a.c., 62-604.400 and 62-610.469
- (7) Do not encase piping in concrete unless specifically authorized.
- (8) All piping shall clear other construction by 6" minimum.

## LOCATION OF PUBLIC WATER SYSTEM MAINS IN ACCORDANCE WITH F.A.C. RULE 62-555.314

Disclaimer - This document is provided for your convenience only. Please refer to F.A.C. Rule 62-555.314, 62-604.400 and 62-610.469 for additional construction requirements, and most current standards.

NOT TO SCALE



LEESBURG

The Lakefront City

# City of Leesburg Standard Details

2024

Detail W-17